



CLARIFICATION NO. 1

3RD ST AND HUNTINGTON RD DRAINAGE EXTENSION

In response to inquiries made by Bidding Documents holders, Deschutes County Road Department (Agency) is providing the following clarification for the above-referenced project:

SUBSURFACE CONDITIONS

Agency has not prepared a geotechnical report for the Project. During previous phases of constructing storm sewer in the vicinity of the Project, common excavation conditions were encountered (as defined by Subsection 00405.02 of the 2018 Standard Specifications), and no physical conditions of an unusual nature were encountered that would differ materially from those ordinarily encountered and generally recognized as inherent to trench excavation.

CONSTRUCTION SURVEY

Agency will perform construction survey work for this project.

Cody Smith, PE
County Engineer

Date

Bidders are not required to acknowledge receipt of this clarification.