



ADDENDUM 3

Date: March 20, 2025

To: All Proposal Document Holders

CORRECTIONAL FACILITY SYSTEM CONTROL PANEL:

QUESTIONS

The following information does not change the details of the Request for Proposal and is provided for informational purposes only.

- Q1: Can the County confirm the license types for each machine? Are they Enterprise (on premise) or Flex (Sas)?
A1: If this is for the control workstations and servers, they are all on-prem. Workstations are running Windows 10 Pro, Servers are running Window Server 2019.
- Q2: What is the current response time of command out of inputs back to the HMI?
A2: Unknown – preference would be as fast as possible
- Q3: Does the County have GE PLC and Omron programming software onsite?
A3: No. We would prefer replacement PLC be identical, not different.
- Q4: Does the County have full PLC and HMI backups? If so, are they runtime only backups? Or does the County have the development images?
A4: We have server and client full backup images as captured by Acronis.
- Q5: Are bonds required?
A5: No.
- Q6: A question came in and provided a picture and asked this question. Are these the existing GR2400's currently installed? If not, please let me know what you are using for lighting control integration.
A6: The picture was not of our facility however we provided several pictures labeled South HV which are of the South High Voltage room lighting pictures. I have attached the manual for the LC&D GR2400 we use.

The south is running on the LC&D GR2400 system. The middle and north (older jail) is conventional lighting with relays to control power to lights. The relays are to be replaced by the vendor and a new solution for light control proposed.

Q7: Who is covering the shipping for owner provided equipment to our shop.

A7: We will ship equipment to the shop. Most likely from the manufacturer.

Q8: Will there be an owner witnessed shop test required.

A8: Yes, we do require a lab demo before sign off and implementation.

Q9: Is this a prevailing wage project?

A9: No this is not a public works project or a major renovation project as defined by ORS 279C.800(6)(a) and OAR 839-025-0004(25)(a).

The original deadline for proposal submissions identified in the RFP for this project is still applicable, March 27, 2025 at 5:00 PM.

Signed by
Heather Herauf
Procurement Manager